

LEAD AND COPPER TESTING CONDUCTED AT MISERICORDIA UNIVERSITY

		EPA ACTION LEVEL IS GREATER THAN 15 PARTS PER BILLION
TEST LOCATIONS	TEST DATE	TEST RESULTS
MERCY 1ST FLOOR MENS REST ROOM	9/29/2022	<1 PPB
MERCY 1ST FLOOR LADIES REST ROOM	9/29/2022	<1 PPB
GILDEA 1ST FLOOR MENS REST ROOM	9/29/2022	<1 PPB
GILDEA 1ST FLOOR LADIES REST ROOM	9/29/2022	<1 PPB
MCAULEY 1ST FLOOR MENS REST ROOM	9/29/2022	<1 PPB
MCAULEY 1ST FLOOR LADIES REST ROOM	9/29/2022	1.5 PPB
GILDEA STUDENT LOUNGE	9/29/2022	<1 PPB
MCAULEY STUDENT LOUNGE	9/29/2022	1.8 PPB
MERCY STUDENT LOUNGE	9/29/2022	16.3 PPB
GILDEA FACILITIES ROOM	9/29/2022	1400 PPB
SAME 10 LOCATIONS RETESTED ON 11/1/22		
MERCY 1ST FLOOR MENS REST ROOM	11/1/2022	<1 PPB
MERCY 1ST FLOOR LADIES REST ROOM	11/1/2022	<1 PPB
GILDEA 1ST FLOOR MENS REST ROOM	11/1/2022	<1 PPB
GILDEA 1ST FLOOR LADIES REST ROOM	11/1/2022	<1 PPB
MCAULEY 1ST FLOOR MENS REST ROOM	11/1/2022	<1 PPB
MCAULEY 1ST FLOOR LADIES REST ROOM	11/1/2022	<1 PPB
GILDEA STUDENT LOUNGE	11/1/2022	<1 PPB
MCAULEY STUDENT LOUNGE	11/1/2022	<1 PPB
MERCY STUDENT LOUNGE	11/1/2022	<1 PPB
GILDEA FACILITIES ROOM	11/1/2022	<1 PPB
ADDITIONAL LOCATIONS SAMPLES ON 12/6/22		
ALUMNAE HALL ROOM 207	12/6/2022	<1 PPB
ALUMNAE HALL ROOM 216	12/6/2022	<1 PPB
ALUMNAE HALL ROOM 229	12/6/2022	<1 PPB
MCGOWAN HALL ROOM 104	12/6/2022	<1 PPB
MCGOWAN HALL ROOM 107	12/6/2022	<1 PPB
MCGOWAN HALL ROOM 307	12/6/2022	<1 PPB

MCGOWAN HALL ROOM 407	12/6/2022	<1 PPB
2ND FLOOR LOUNGE KITCHEN	12/6/2022	<1 PPB
4TH FLOOR LOUNGE KITCHEN	12/6/2022	<1 PPB
BANKS KITCHEN 1	12/6/2022	<1 PPB
BANKS KITCHEN 2	12/6/2022	<1 PPB
BANKS KITCHEN 3	12/6/2022	<1 PPB
STARBUCKS KITCHEN	12/6/2022	<1 PPB
WATER COOLER STUDENT LIFE	12/6/2022	<1 PPB
MCDOWELL SINK CLASSROOM 104	12/6/2022	<1 PPB
MCHALE HALL KITCHEN LOUNGE	12/6/2022	<1 PPB
MCHALE HALL BOTTLE FILLER BY 231	12/6/2022	<1 PPB
MCHALE HALL BOTTLE FILLER BY 302	12/6/2022	<1 PPB
MCHALE HALL BOTTLE FILLER BY 431	12/6/2022	<1 PPB
GILDEA HALL 1ST FLOOR WATER COOLER	12/6/2022	<1 PPB
GILDEA HALL 2ND FLOOR KITCHENETTE	12/6/2022	<1 PPB
GILDEA HALL 3RD FLOOR KITCHENETTE	12/6/2022	<1 PPB
GILDEA HALL 4TH FLOOR KITCHENETTE	12/6/2022	<1 PPB
INSALACO HALL 1ST FLOOR WATER FOUNTAIN	12/6/2022	<1 PPB
INSALACO HALL 2ND FLOOR KITCHEN	12/6/2022	<1 PPB